

**PRE-CONSTRUCTION RFI LOG**

**PROJECT** New Career and Technical Education Center (Package 2)



**OWNER** Lamar CISD

**ARCHITECT** Stantec

**JOB #** 23-790

**DATE** 06/19/24

**Updated:**

No.	Discipline	Description	Drawing Sheet	Specification Section	Date Submitted	Response Date	Response
<b>A GENERAL</b>							
<b>B CIVIL</b>							
<b>C STRUCTURAL</b>							
<b>D ARCHITECTURE SITE</b>							
1	Fences & Gates	Fence Callouts refer to detail A4/AS007 for fence detail and B1/AS007 for gate detail. Is this suppose to be A1/AS006 & B1/AS006	AS006, AS007	N/A	06/19/24	2024.06.20	Updated in Addendum 2
2	Fences & Gates	Please provide specifications for Chainlink Fences & Gates	N/A	N/A	06/19/24	2024.06.20	Spec section issued in Addendum 2
3	Handicap Signage	Subcontractor Question: What size are the handicap tubes? I see 12" X ? X 9'	D3/AS004	N/A	06/19/24	2024.06.20	Updated in Addendum 2
<b>E ARCHITECTURE</b>							
1	Metal Shelving	Subcontractor Question: We are planning to bid metal shelving, wire mesh partitions and steel pallet racks (10 28 10, 2.4) Spec calls for racks to be 108 w. x 144 h. Sheet A731 elev. A3 shows 144 w. x 192 h. Which is correct? Please advise.	10 28 10	A731	06/19/24	2024.06.20	Rack to be 144w x 144h x 42d - Detail A3/A731 will be updated in Addendum 2
2	Glazing	Subcontractor Question: Please supply elevation for GWP-2 glass on Page A828 detail D5.	A828	N/A	06/19/24	2024.06.20	 Per Material Schedule A801
3	Glazing	Subcontractor Question: Please supply elevation for GWP-2 glass in room C126.	A713	N/A	06/19/24	2024.06.20	 Per Material Schedule A801
4	Access Floor	Subcontractor Question: There's a spec section for Access Floor (096900) but I cannot find any on the drawings. Is this in there by mistake?	N/A	09 69 00	06/19/24	2024.06.20	Provide access floor at Graphic Design Lab B136 & Video Production C106 - to be clarified in Addendum 2
<b>F FIRE PROTECTION</b>							
1	Paint/Spray Booth	Subcontractor Question: I downloaded the 80% CD – Package 2 plans for the new career and technical education center and could not find plans for the following:  PRE-FABRICATED SELF CONTAINED PAINT/SPRAY BOOTH.  Are there any plans for the paint/ spray booth and specifications available? Does the design team want a chemical system or wet sprinkler system priced?	N/A	N/A	06/19/24	2024.06.20	Paint Booth is NIC - provided by owner  <a href="#">Paint Booth: Tuxedo Distributors Cross Flow Paint Booth 22.6L-13W-8.6H 1PH-230V PSB-AFCF23B-1PH-230V-AK (eastwood.com)</a>
<b>G PLUMBING</b>							
<b>H MECHANICAL</b>							
<b>I ELECTRICAL</b>							

No.	Discipline	Description	Drawing Sheet	Specification Section	Date Submitted	Response Date	Response
J	FIRE ALARM SYSTEM						
K	TECHNOLOGY						
1	Audio-Video	Subcontractor Question: Spec Section 276105 Audio Video Systems and Equipment mentions spec 276100 Integrated Audio-Video Systems & Equipment for Instructional Spaces. However, Spec 276100 AV for Instructional Spaces does not appear to have been provided. Please provide this document.	N/A	27 61 05	06/19/24		
L	FOOD SERVICE						
M	LANDSCAPING & IRRIGATION						